

LICENCE

No. 15939 replaces No.15717

Issued to:
Applicant:
Preflexibel
Elisabethlaan, 153
9400 NINOVE
Belgium

CEBEC

Licensee:
Preflexibel
Elisabethlaan, 153
9400 NINOVE
Belgium

Product : conduit systems for cable management

Trade name(s) : PREFLEXIBEL

Type(s)/model(s) : PRF 16, PRF 20, PRF 25

The product and any acceptable variation thereto is specified in the annex to this licence and the documents therein referred to.

SGS CEBEC hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard specified in annex
- an inspection of the production location
- a certification agreement with the number 1235

SGS CEBEC hereby grants the right to use the CEBEC certification mark. The CEBEC certification mark may be applied to the product as specified in this licence for the duration of the CEBEC certification agreement and under the conditions of the CEBEC certification agreement.

This licence is issued on:

05/02/2009

ir. C. Lana, Certification Manager

© Only integral publication of this certificate, including the annex, is allowed
This certificate is only valid combined with the publication on the following web address: www.sgs.com/ee







SGS Belgium NV-Division SGS CEBEC Business Riverside Park Bld Internationalelaan 55 Build. D B-1070 Brussels Tel.+32(0)2 556 00 20 Fax.+32(0)2 556 00 36 This certificate is issued by the company under its General Conditions for Certification Services accessible at http://www.sgs.com/terms_and_conditions.htm. Attention is drawn to the limitations of liability defined therein and in the Test Report herein mentioned which findings are reflected in this Certificate. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.



SPECIFICATION OF THE CERTIFIED PRODUCT

Product data

Product : conduit systems for cable management

Trade name(s) : PREFLEXIBEL

Type(s)/Model(s) : PRF 16, PRF 20, PRF 25

description : Conduit systems for electrical installations

Pliable self recovering conduits

nominal size(s) (outside diameters) : 16, 20, 25 mm

classification : 3422

type of conduit : non-metallic / corrugated

method of connection : non-treadable

resistance to bending : pliable / self-recovering
Fire propagation (F2) : non flame propagation

colour(s) grey

Additional information

CLASSIFICATION CODING

First digit: 3 Medium compression strength 750 N Second digit: 4 Medium impact strength 2 kg/300 r

Second digit: 4 Medium impact strength 2 kg/300 mm

Third digit: 2 Minimum permanent application -5°C

and installation temperature

Fourth digit: 2 Maximum permanent application +90°C

and installation temperature

Fifth digit: 3 Resistance to bending Pliable/self-recovering

TESTS

Test requirements

NBN EN 61386-1 based on EN 61386-1:2004 NBN EN 61386-22 based on EN 61386-22:2004

Test results

The test results are laid down in test report(s) ref. 578795.03



ANNEX TO CEBEC LICENCE No. 15939 Page 2 of 3

Conclusion

The examination proved that all test requirements were met.

Checked by, project leader : Zanutto Luigi - 05/02/2009

Department Manager, Product Certification

Certification Manager :



ANNEX TO CEBEC LICENCE No. 15939 Page 3 of 3

FACTORY LOCATION(S)

Preflexibel Elisabethlaan, 153 9400 NINOVE Belgium